

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

ನಂಖ್ಯೆ:ಕಾಳಿಂಗ್.ಕು.ನೀ&ನ್ಯೂ:ವರ್ತಿ:25-26 /826

Date : 29 /7/2025

It is certified that an inspection team headed by Rajshekhar, A.E,QM from R.D.W&S inspected the PRAJNA EDUCATION TRUST (R), PACE INTERNATIONAL,SCHOOL, Teverachetnahalli, Honnali Road ,Shivamogga on 21/07/2025 and on the basis of water test report (attached) bearing Report No. SMG25JUL0020 dated 19/07/2025 of District Water Quality Testing Laboratory, RDWSD, Shivamogga Certified that the PRAJNA EDUCATION TRUST (R), PACE INTERNATIONAL,SCHOOL. has safe drinking water facilities for the student and members of staff of the institution. the school also maintain the hygienic sanitation condition in the school building & campus as per norms prescribed by the central/state/U.T.Govt.

This certificate is valid till 18/07/2026

  
**Executive Engineer**  
R.D.W. & S. Division, SHIMOGA.

Designation: Executive Engineer

Name & Address of the Ofice/Depatment:  
RDW&SD,Division,Shivamogga.

To,  
PRESIDENT  
PRAJNA EDUCATION TRUST (R),  
PACE INTERNATIONAL,SCHOOL  
Teverachetnahalli, Honnali Road ,  
Shivamogga.

Note: The certificate is to be issued by authorized officer / PHED lab / local bodies.



**RURAL DRINKING WATER & SANITATION DEPARTMENT**  
Shivamogga District Level Water Quality Testing Laboratory  
DC Compound, RTO Office Road, Shivamogga-577201

**TEST REPORT**

|   |   |           |  |  |                                |
|---|---|-----------|--|--|--------------------------------|
| <b>Address :</b><br>M/S. PRESIDENT<br>PRAJNA EDUCATION TRUST (R)<br>PACE INTERNATIONAL SCHOOL<br>TEVARA CHATNAHALLI, HONNALI ROAD,<br>SHIVAMOGGA. |   |           |  | Report date: 19.07.2025<br>ULR Number: TC-145882400000415F<br>Report Number: 0415<br>Reference: TRF<br>Sample receipt date: 15.07.2025<br>Sample code: SMG25JULS0020<br>Date of Sample collection: 15.07.2025<br>Analysis start date: 16.07.2025<br>Analysis completion date: 18.07.2025<br>Sample collection Method: CUSTOMER |                                |
| <b>Sample Particulars:</b> Drinking Water.  |   |           |  | Sample quantity: 1 litre   |                                |
| Sl.No   | Test  | Results   | Acceptable Limit IS 10500 : 2012 RA:2018                       | Permissible Limit IS 10500 : 2012 RA:2018  | Test Method                    |
| Description: Clear Sample   |   |           |  |  |                                |
| 1   | Odour   | Agreeable | Agreeable  | Agreeable  | IS 3025 (Part-5):2018          |
| 2   | Taste   | Agreeable | Agreeable  | Agreeable  | IS 3025 (Part-8):2023          |
| 3   | Colour, Hazen Units   | <5        | 5  | 15   | IS 3025 (Part-4) :2021         |
| 4   | Turbidity, NTU  | 0.2       | 1  | 5  | IS 3025 (Part-10) : 2023       |
| 5   | pH Value @25°C  | 7.47      | 6.5 – 8.5  | No relaxation  | IS 3025 (Part-11) :2022        |
| 6   | Total Dissolved Solids @ 105°C, mg/l  | 192       | 500  | 2000   | IS 3025 (Part-16) : 2023       |
| 7   | Alkalinity as CaCO <sub>3</sub> , mg/l  | 132       | 200  | 600  | IS 3025 (Part-23) : 2023       |
| 8   | Chloride as Cl, mg/l  | 28.7      | 250  | 1000   | IS 3025 (Part-32) : 2019       |
| 9   | Fluoride as F, mg/l   | 0.12      | 1  | 1.5  | APHA 24 <sup>th</sup> Edition  |
| 10  | Nitrate as NO <sub>3</sub> , mg/l   | 4.1       | 45   | No relaxation  | APHA 24 <sup>th</sup> Edition  |
| 11  | Sulphate as SO <sub>4</sub> , mg/l  | 7.2       | 200  | 400  | IS 3025 (Part-24/Sec 1) : 2022 |
| 12  | Calcium as Ca, mg/l   | 22.4      | 75   | 200  | IS 3025 (Part-40) : 2019       |
| 13  | Magnesium as Mg, mg/l   | 10.7      | 30   | 100  | IS 3025 (Part-46) : 2023       |
| 14  | Total Hardness as CaCO <sub>3</sub> , mg/l  | 100.1     | 200  | 600  | IS 3025 (Part-21) : 2023       |
| 15  | Iron as Fe, mg/l  | 0.09      | 1  | No relaxation  | IS 3025 (Part-53) : 2024       |
| 16  | Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C                                 | 295       | –  | –  | IS 3025 (Part-14) :2019        |
| <b>Remarks:</b> The above tested parameter conforms to the Acceptable limits of IS 10500:2018 Drinking Water Specification .                      |   |           |  |  |                                |
| Analysed by:<br>Junior Analyst<br>(Sunil Kumar N S)   |  |           | Authorized Signatory:<br>Technical Manager<br>(Punith Kuamr H) |    |                                |

RDWSD/WQMSP/TeR/01

.....END OF THE REPORT.....

**Note:**

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) **Traceability:** Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.